

Inspection Summary

Permit #: PRSUBD20203599, Development - Subdivision
Whispering Woods 2nd Plat
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Pavement-Stabilized Subgrade	Steve Robbins	Passed	Wednesday, April 14, 2021

Informational

1 The stabilized subgrade was installed last Tuesday 4/6. Portland was the chemical subgrade that was used. The geotechnical engineer approved the amount used. We are planning doing. A proofroll on the stabilized subgrade at 3 this afternoon.

Informational

2 The proofroll passed except for 2 small area's that we added rock on this morning and did another proof roll that passed for the stabilized subgrade only.

Comments: