

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20203605

Address: 500 NW OLIVE ST, LEES SUMMIT, MO 64063412 NW OLIVE ST, LEES SUMMIT, MO 64063408 NW  
OLIVE ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Air Test</b>	Joe Starlin	Passed	Thursday, April 15, 2021

Informational:

1 Misc

4-14-21 12:13pm testing A5 to A4. The gauge is at 4.0 This section has passed. We are now testing from A-4 to A-3. This section has passed. We are now testing from A-3 to A-2. This section has failed at this time. 3pm They set up from manhole A-2 to A-1. It has passed.  
4-15-21 11:10am We are testing from A-3 to A-2. It has passed.

**Comments:**