

# Inspection Summary

Permit #: PRSUBD20203599, Development - Subdivision  
Whispering Woods 2nd Plat  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

## Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	John DiMauro	Passed	Wednesday, April 14, 2021

## Informational

- 1 The aggregate base rock (MO Type 5) has been installed and is setting up to be ready for a proof roll for curb installation.

Pavement-Stabilized Subgrade	Steve Robbins	Passed	Wednesday, April 14, 2021
---------------------------------	---------------	--------	------------------------------

## Informational

- 1 The stabilized subgrade was installed last Tuesday 4/6. Portland was the chemical subgrade that was used. The geotechnical engineer approved the amount used. We are planning doing. A proofroll on the stabilized subgrade at 3 this afternoon.

## Informational

- 2 The proofroll passed except for 2 small area's that we added rock on this morning and did another proof roll that passed for the stabilized subgrade only.

## Comments: