CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20210540

Address: 4413 SW TANZANITE CIR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection: Outcome: Date:

Footing Inspection - Patrick Schonfeldt Failed - Stop Work Friday, April 16, 2021

Residential

Corrective Action Required

1 Misc -FOOTING POURED WITHOUT INSPECTION, SUBMIT ENGINEER

REPORT, REPORT REQUIRED TO BE UPLOADED TO PERMIT

WITHIN 2 DAYS OF INSPECITON

Comments: