

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20211035
Address: 4412 SW ALABASTER CIR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed - Stop Work	Friday, April 16, 2021

Corrective Action Required
1 Misc

-FOOTING POURED WITHOUT INSPECTION, SUBMIT ENGINEER
REPORT, REPORT REQUIRED TO BE UPLOADED TO PERMIT
WITHIN 2 DAYS OF INSPECITON

Comments: