CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #:PRRES20210595Address:4409 SW ALABASTER CIR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such

work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfe	ldt Failed - Stop Work	Friday, April 16, 2021
Corrective Action Requ	uired		
1 Misc	-FOOTING POURED WITHOUT INSPECTION, SUBMIT ENGINEER		
	REPORT, REPORT REQUIRED TO BE UPLOADED TO PERMIT		
	WITHIN 2 DAYS OF INSPECTION		

Comments: