

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210484
Address: 3552 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|--------------------|----------|------------------------|
| Above Ceiling Inspection | Patrick Schonfeldt | Failed | Friday, April 16, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -SECURE/SUPPORT ALL MC UP OFF THE CEILING GRID - SEE AREA BACK AROUND MECHANICAL CLOSET -SECURE ALL MC WITHIN 12" OF JUNCTION BOXES -MC CABLE SHALL BE SUPPORTED AT INTERVALS NOT EXCEEDING 6' |
|---|------|--|

Comments: