

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211596
Address: 1862 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, April 16, 2021

Corrective Action Required:

1	Misc	-FB FLOOR AT PLUMBING TRAP; FB WALL SPACE VERTICALLY AT TEN FT OR LESS INTERVAL; FB WALL SPACE FROM HORIZONTAL SPACE, SUCH AS SOFFITS, FUR DOWN SPACE. -STAPLE WIRING MIN 1.25" ABOVE JOIST BOTTOM
---	------	---

Comments: