

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210744
Address: 2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Partial	Friday, April 16, 2021

Corrective Action Required:

1	Misc	- PROVIDE 3RD PARTY INSPECTION FOR DRILLED PIERS WITHIN 48 HOURS OF POUR - - OK TO POUR FOOTING -
---	------	--

Comments: