

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210948  
Address: 306 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Michael Harkins	Failed	Monday, April 19, 2021

Corrective Action Required:

1	Misc	- PROVIDE ADDRESS - - PROVIDE HELIX OPTION DETAIL SHEET ( PLANS SHOW TWO #4 BARS CONTINUOUS ) : 3RD PARTY: - : 3RD PARTY FOOTING BY COLBY SHAW @ RES SIGNED & SEALED BY BRADLEY HUXOL ( NO SUBGRADE REPORT, SOIL BEARING NOT ADDRESSED ON 3RD PARTY FOOTING ) - PROVIDE ENGINEER'S SUBGRADE INSPECTION REPORT -
---	------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: