

## ANALYTICAL REPORT

April 01, 2021

Work Order: 1EC2579

Page 1 of 3

Report To
Steve Robbins City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 03/31/2021 1:10PM Collector: Robbins, Steve Phone: (816) 969-1200 PO Number: Routine Analysis

Project : Earth Works Excavation

Project Number: Cobey Creek

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
<b>1EC2579-01</b> #1				Matrix:Drink Wtr		Collected: 03/31/21 11:30	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
<b>1EC2579-02</b> #2				Matrix:Drink Wtr		Collected: 03/31/21 11:35	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
<b>1EC2579-03</b> #3				Matrix:Drink Wtr		Collected: 03/31/21 11:41	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
<b>1EC2579-04</b> #4				Matrix:Drink Wtr		Collected: 03/31/21 11:44	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
<b>1EC2579-05</b> #5				Matrix:Drink Wtr		Collected: 03/31/21 11:50	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
<b>1EC2579-06</b> #6				Matrix:Drink Wtr		Collected: 03/31/21 11:58	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
<b>1EC2579-07</b> #7				Matrix:Drink Wtr		Collected: 03/31/21 12:06	
Total Coliforms	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1EC1523	9223B-QT	CLJ	03/31/21 16:30	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.  
220 SE Green Str  
Lees Summit, MO 64063

April 01, 2021  
Page 2 of 3

Work Order: 1EC2579

**Certified Analyses included in this Report**

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

  

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2021
MO-KC	Missouri Department of Natural Resources	140	04/30/2021
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager

