

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20210199	Date:	April 20, 2021
Project Title:	SUMMIT WOODS CROSSING - WHITE BOX	Applicant:	
Location:	1740 NW CHIPMAN RD, LEES SUMMIT, MO 64081	ABSOLUTE FIRE INC	
Type of Work:		13906 CENTURY LN	
Occupancy Group:	UC	GRANDVIEW, MO 64030	
Description:	CONSTRUCT WHITE BOX FOR FUTURE TENANT THAT SELLS FITNESS EQUIPMENT	Primary:	(816) 737-9991
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.