

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204880  
Address: 342 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Failed	Tuesday, April 20, 2021

Corrective Action Required:

1	Misc	- PROVIDE HEALTH DEPT APPROVAL - - PROVIDE ADDRESS REAR DOOR - - PROVIDE REAR EXIT SIGN - - PROVIDE 18" VERTICAL GRAB BAR RESTROOM - - PROVIDE INSULATION PLUMBING UNDER SINK - - POS COUNTERTOPS HEIGHT PER PLAN - - PLANS SHOW DECK AT REER DOORS NO DECK WOOD STAIRS NEED BALUSTERS IF DECK NOT REQUIRED -
---	------	--

**Comments:**