

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201210
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Wednesday, April 21, 2021

Corrective Action Required:

1	Misc	-Provide engineers report regarding vertically drilled LVL headers at both portal openings -Provide engineers report regarding proper joist/rafter/top plate fastening throughout
---	------	--

Comments: