

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204750  
Address: 2005 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, April 21, 2021

Corrective Action Required:

1	Misc	- PROVIDE GAS PIPING SUPPORT PER IRC G2424 IFGC 415.1 - - PRESSURE STEADY AT 18 PSI -
---	------	---------------------------------------------------------------------------------------------

**Comments:**