

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200845

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, April 21, 2021

Corrective Action Required:

1 THE FOLLOWING
AREAS ARE
APPROVED

THE FOLLOWING AREAS ARE APPROVED TO COVER:

ROOMS-, 49,60,61
ROOM 77A,77B-
ROOMS 110A,111A,112A,113A,114A,115A,116A,117A,118A;
PATIENT ROOMS 110-118, 81,83,85,87,89,91,93,95,96,98,100,102,104,106
HARD LIDS UNIT BATHROOMS-081A, 083A, 085A, 087A, 089A, 091A, 093A,
095A, 096A, 098A, 100A, 102A, 104A, 106A,
WORK STATION 1B099,1B135, 1B119
HARD LIDS AT: NOURISH 1B133, STRETCHER/ EQUIPT STORAGE 1B120
NURSE'S STATION 1B088 SOFFITS
BREAK ROOM 068
FAST TRACK 069, 071, 072, 073
TRAUMA 109
CORRIDORS 1B00N, 1B00P TO JUST PAST ROOM 106, 1B136, 1B00O, 1B00M,

EMERGENCY:
TOILETS 1B001, 1B002, 1B009
TRIAGE 1B003, 1B004, 1B005
CORRIDOR B102 TO LINE BC

WAITING 1B00C TO LINE BC.6
RECEPTION 1B007
CONSULT 1B008
VESTIBULE 1B00D

HARD LIDS IN PATIENT BATHROOMS:163-166A, 152-154, 150, 1551A, 107A
SOFFIT AT NURSE STATION 158
PATIENT ROOMS 163-166, 150-154, STORAGE 155, MED 156, RM 158,159

Corrective Action Required:

2

Misc

-SEAL THROUGH PENETRATIONS AT 160,161,167
-SEAL SMOKE WALL AT 162, OUTSIDE OF 153
-LABEL SMOKE WALL CORRIDOR 168

Comments: