

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211100
Address: 159 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Partial	Wednesday, April 21, 2021

Informational:

1 Misc

- 4/19/21 - 1st layer rock inspected on demising wall
-4/21/21 - 2nd layer rock inspected on demising wall

****Firecaulk all penetrations in assembly and along roof deck/sheetrock gaps****

****Mark firewall per 703.7, min 3" letters located within 15' of ends of walls and intervals not exceeding 30' horizontally along wall****

Comments: