

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20203248

Address: 1401 NW VIEW HIGH DR, LEES SUMMIT, MO 64081
1195 NW VIEW HIGH DR, LEES SUMMIT, MO 64081
640811201 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	John Jackson	Passed	Wednesday, April 21, 2021

Informational:

1	Misc	3/11/21 Thursday Contractor (Clarkson - Gregg crew) collected samples from Line D & A . Line A permit #PRSUBD20202246.
---	------	--

Informational:

2	Misc	Water samples were taken on 4/19 it passed.
---	------	---

Comments: