

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20200599
Address: 3104 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Stabilized Subgrade	Tom Taylor	Passed	Thursday, October 22, 2020

Informational:

1	Misc	On Thursday, 10-22-2020. Spalding Excavating finished the Portland sub-grade stabilization and compaction installation. Kansas City Testing provided all density testing that passed with reading from 95% to 100% compaction.
---	------	--

Comments: