

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20200599  
Address: 3104 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Stabilized Subgrade</b>	Tom Taylor	Partial	Tuesday, November 03, 2020

Informational:

1 Misc

On Thursday, 10-22-2020. Spalding Excavating finished the Portland sub-grade stabilization and compaction installation. Kansas City Testing provided all density testing that passed with reading from 95% to 100% compaction.

Informational:

2 Misc

On Tuesday, 11-03-2020. Spalding Excavating installed type 5 aggr. Base and compacted to sub-grade.

**Comments:**