

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20200599  
Address: 3104 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Tom Taylor	Passed	Monday, January 18, 2021

Informational:  
1 Misc On Tuesday, 1-12-2021, Redford Excavating provided 2nd water sample and are still waiting on results for first sample.

Informational:  
2 Misc On Friday 1-15-2021. The test results for the water samples taken earlier in week tested negative for bacteria and passed all water installation.

**Comments:**