

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20200599
Address: 3104 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Tom Taylor	Partial	Tuesday, January 12, 2021

Informational:
1 Misc On Tuesday, 1-12-2021, Redford Excavating provided 2nd water sample and are still waiting on results for first sample.

Informational:
2 Misc On Friday 1-15-2021. The test results for the water samples taken earlier in week tested negative for bacteria and passed all water installation.

Comments: