

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203927
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Morris	Failed	Thursday, April 22, 2021

Informational:

1 Misc

-PHASED OCCUPANCY APPROVALS-
-Restrooms approved for occupancy. 03/10/2021 JM Codes/Fire
-Office area approved for occupancy 03/18/2021 JM Codes/Fire

Corrective Action Required:

2 Misc

-install outlet covers in market grille and deli
-install panel covers on wine and spirits side
-install beverage backflow devices
-install cleanout caps at market grille and deli
-install and secure equipment under market grille kitchen hood

Comments: