

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210056  
Address: 3049 NW THOREAU LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Thursday, April 22, 2021

Corrective Action Required:

1	Misc	Nail 2x4 on bottom of LVL as per plans, 2 rows 3" O.C. - nail OSB per plans, top and edge needs to be nailed.
---	------	--

Comments: