

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210880  
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Michael Harkins	Failed	Friday, April 23, 2021

Corrective Action Required:

1	Misc	Column pad D plans shows 48 x 48 w/ 8 #4 bars EW chair up mats Column pad F calls for 10 # 4 bars EW chair up mats Provide sub grade report ( assumed 2000 PSF bearing to be verified by geotechnical engineer per plan ) Ufer location center of foundation wall rear of garage
---	------	---

Comments: