

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202176
Address: 1520 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Patrick Schonfeldt	Failed	Friday, April 23, 2021

Corrective Action Required:

1	Misc	-UNCOVER AND RAISE TO GRADE IF NECESSARY MANHOLE MH 5-1 AS SHOWN ON PLOT PLAN AT FRONT OF LOT-
---	------	--

Comments: