

SAB Construction

Avere

Air Combustion Calculation				
Per IRC 2018 G2407.5.1				
Fuel Burning Appliance #1 - Furnace #1	Furnace	100000	Btu/h	
Fuel Burning Appliance #2 - Furnace #2	Furnace	0	Btu/h	
Fuel Burning Appliance #3 - Water Heater #1	WH	50000	Btu/h	
Fuel Burning Appliance #3 - Water Heater #2	WH	0	Btu/h	
Total Btu/h		150000	Btu/h	
Area of useable space		810	sq.ft	
Ceiling height in useable space (no sheetrock)		9	ft	
Volumne of space		7290		
Required Volume of Air = total Btu/h * (50 cu.ft/1000 Btu/h)		7500	cu.ft.	
Required Area of Usable Space		833	sq.ft.	
Standard Method of Work?		BAD		
Combustion Air Transfer Grille				
Per IRC G2407.5.3.1				
Required Opening Free Space = 1 sq.in./1000 Btu/h				
	=	160	sq.in.	
Size of grille to be used	=	(2) 14"x8"		
Note: If fuel burning appliances are enclosed, (1) opening is required within 12" of floor and (1) opening is required within 12" of top enclosure				

SAB Construction