

Temporary Certificate of Occupancy

Permit #: PRRES20201853
Address: 514 NW MAIN ST, LEES SUMMIT, MO 64063
Inspected On: Monday, April 26, 2021
Inspected By: Robb Popp
Expiration Date: 5/24/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Monday, April 26, 2021

Corrective Action Required:

- Miscellaneous *TCO until 5-24-21
Correction
 - Driveway inspection still pending
 - Provide erosion control until sod is in place
 - Final grade and sod
 - Seal meter can, ac disconnect, and all other exterior penetrations
 - Lights at front and back door to be sealed fixtures per security code
 - Provide sidewalks or resolve with city