



PLAN REVIEW CONDITIONS

April 26, 2021

JOE STEWART
125 HIGHLAND PARK AVE
EXCELSIOR SPRINGS, MO 64024

Permit No: PRCOM20212011
Project Title: RALLY HOUSE
Project Address: 1712 NW CHIPMAN RD, LEES SUMMIT, MO 64081
Parcel Number: 51700031300000000
Location: CHIPMAN HWY 50--- LOT 12
Type of Work: CHANGE OF TENANT
Occupancy Group:
Description: TENANT FINISH FOR SPORTS THEMED RETAIL

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Approved

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide two 2A10BC Fire Extinguishers

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.