CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203515

Address: 2600 SW WARD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Water Service Inspection Tom Taylor Partial Thursday, March 04,

2021

Corrective Action Required:

1 DCM8 Water Meter THE TOP OF THE WATER METER TO BE SET AT A DEPTH OF 14 TO 18 INCHES

Height BELOW THE WATER METER LID.

Corrective Action Required:

2 DCM8 Water Meter THE TOP OF THE WATER METER TO BE SET AT A DEPTH OF 14 TO 18 INCHES

Height BELOW THE WATER METER LID.

Informational:

3 Misc On Wednesday, 3-03-2021. Contractor Pro Design began installation of the 6"

water main tie - in. The contractor installed the vault for the back flow valves. The contractor exposed the existing 6" cast iron line and notified the Water Services Dept. that they needed the 2" tap for the domestic line to

installed.

Comments: