

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204750
Address: 2005 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|-----------|-------------------------|
| Gas Service Inspection - Residential | Michael Harkins | Not Ready | Tuesday, April 27, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | - PROVIDE GAS PIPING SUPPORT PER IRC G2424 IFGC 415.1 - - PRESSURE STEADY AT 18 PSI - |
|---|------|---|

Comments: