

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202177
Address: 1801 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	John Morris	Failed	Tuesday, April 27, 2021

Corrective Action Required:

1	Misc	-water meter pit lid to be at grade level and meter to be 14-18" below lid -water valve box lids to be at grade level, repair damaged risers & lids and remove debris from risers
---	------	--

Comments: