

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201014
Address: 2751 NE DOUGLAS ST, Unit:V, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, April 27, 2021

Corrective Action Required:

1	Misc	-Steel columns protruding into egress path. Provide compliance with ANSI 117 307&403 -The 2-hour fire barrier for the furnace closet is required. Submit all changes to plan examiner -Complete building exits
---	------	--

****OK TO ROCK**

Comments: