

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203775
Address: 2338 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Wednesday, April 28, 2021

Corrective Action Required:

1	Misc	Erosion control requires continuous maintenance, repair damage sections within 48 hours. Immediate Street clean up required. No further inspections until resolved
---	------	--

Comments: