




April 27, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field issue of notched (2) #2 2x10 for front porch roof for Lot # 93 Reserve at Stoney Creek- 4391 SW Amethyst Dr. Lee's Summit, MO 64082- Permit # PRRES20204325

This letter addresses the notched (2) #2 2x10 for front porch roof support.

- 1" tall x 1.5" wide notch in (2) #2 2x10 spanning approximately 6' is structurally acceptable.
- (2) #2 2x10 has negligible loads as truss is not load bearing along beam's length.



Sincerely,

Bradley Huxol, PE

