

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204527
Address: 1519 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, April 28, 2021

Corrective Action Required:

1	Misc	-Address sump pump and AC line bored through joist less than 2" from end of joist at SE corner basement, follow repairs per engineer letter instructions
---	------	--

****OK TO INSULATE****

Comments: