

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210599  
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line - Hydrostatic Test</b>	Joe Starlin	Passed	Wednesday, April 28, 2021

Informational:

1	Misc	4-28-21 8:52am Bair is getting set up for the hydrostatic test for the fire line. 9:31am we have started the test. 11:30am The pressure test held at 200 for two hours. It has passed.
---	------	--

**Comments:**