

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204555
Address: 1817 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, April 29, 2021

Corrective Action Required:

1	Misc	-w8x15 steel beam not bearing full on concrete pocket and supported by 2x6 Engineer report received, will need to inspect pier pad prior to pour
---	------	---

****OK TO INSULATE****

Comments: