

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20203605

Address: 500 NW OLIVE ST, LEES SUMMIT, MO 64063412 NW OLIVE ST, LEES SUMMIT, MO 64063408 NW
OLIVE ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|-------------|----------|--------------------------|
| Sanitary Sewer - Mandrel | Joe Starlin | Passed | Thursday, April 29, 2021 |

Informational:

1 Misc

4-15-21 11:14am We are pulling from A3 to A-4. The mandrel passed through the line but won't go through the invert. We are now testing from A-5 to A-4. It passed. We pulled from A-3 to A-2. It has passed. We are now pulling from A-2 to A-1. It has passed with a correction needed on the invert of A-2.

Comments: