



### **PLAN REVIEW CONDITIONS**

April 29, 2021

R. GARY GLUECK ARCHITECTURE  
3797 LOOP RD  
NASHVILLE, NC 27856

Permit No: PRCOM20211560  
Project Title: SUMMIT ORCHARDS RETAIL CENTER - PETLAND  
Project Address: 460 NW CHIPMAN RD, LEES SUMMIT, MO 64086  
Parcel Number: 52900036200000000  
Location: SUMMIT ORCHARD LOTS 4A-4E --- LOT 4B  
Type of Work: NEW TENANT FINISH  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH FOR PET STORE

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

#### **Fire Plan Review**

**Reviewed By: Michael Weissenbach**

**Approved with Conditions**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Any modifications to the fire alarm system, provide PE stamped electronic shop drawings to [mike.weissenbach@cityofls.net](mailto:mike.weissenbach@cityofls.net)

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)  
Address all exterior doors.

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the fire sprinkler system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofsl.net

4. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

5. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide 2 2A10BC Fire Extinguishers.

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

2. 2018 IBC 502.1 Address identification. New and existing buildings shall be provided with approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. Each character shall be a minimum of 4 inches high with a minimum stroke width of ½ inch. Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building address cannot be viewed from the public way, a monument, pole or other approved sign or means shall be used to identify the structure. Address identification shall be maintained.

Action required: Suite designation for this address not yet assigned. Provide plan, or similar, showing entire building wing and relationship of this suite to the adjacent suites.

3. 2018 IBC 1606.2 Design dead load. For purposes of design, the actual weights of materials of construction and fixed service equipment shall be used. In the absence of definite information, values used shall be subject to the approval of the building official.

Action required: Provide engineer's report to verify that existing roof structure will support additional load or provide design to accommodate new weight from rooftop equipment.

4/29/21 - not addressed

5. Missouri Board for Architects, Professional Engineers, Professional Land Surveyors and Professional Landscape Architects – Board Rules, Division 2030 – Chapter 3, 20 CSR 2030-3.060 Licensees Seal Documents must bear design professionals original seal with signature and date. (relevant portion

paraphrased – reference original document for additional information)

Action required: All drawings are to bear dated seal and signature from architect/engineer of record including MEP sheets.

4/29/21 - MEP still not sealed/signed.

7. 2018 IMC 801.2 General. Every fuel-burning appliance shall discharge the products of combustion to a vent, factory-built chimney or masonry chimney, except for appliances vented in accordance with Section 804. The chimney or vent shall be designed for the type of appliance being ventilated. (see code for exception)

Action required: Provide complete design for water heater combustion and ventilation air.

4/29/21 - Vent shown but nothing found on combustion air. Heater is in a confined location so ambient area is not sufficient.

9. **\*\*This comment added after initial review to address new information that is now on the drawings\*\***  
2018 IPC 604.9 Water hammer. The flow velocity of the water distribution system shall be controlled to reduce the possibility of water hammer. A water-hammer arrestor shall be installed where quick-closing valves are utilized. Water-hammer arrestors shall be installed in accordance with the manufacturer's instructions. Water-hammer arrestors shall conform to ASSE 1010.

Action required: Provide compliant water hammer arrestors as air chambers are not allowed.

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***