

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202946
Address: 2337 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Friday, April 30, 2021

Corrective Action Required:

1	Misc	-Fireblock through floor Penetration, kitchen -Provide safety glazed window, master bedroom -Provide engineer report regarding cracked foundation wall, west side Ok to insulate
---	------	---

Comments: