# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20202240

Address: 2353 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes John Morris Failed Friday, April 30, 2021

Residential

## Corrective Action Required:

1 Misc - Maintenance of erosion control is required until sod is in place

-As graded plot plan required

-Final grade and sod

-Complete gutter/downspout installation

-Downspouts and sump piping to discharge minimum 36 inches from

foundation

-Unable to locate water meter, ensure lid is accessible at grade and meter is

14 to 18 inches below lid

-Seal all exterior penetrations, By electric meter enclosure

-Complete deck stair landing

-Deck post to beam connections per code -Ledger connection to structure per code

-Secure raceway at equipment disconnect termination, condensing unit whip

-Label dedicated circuit in garage as non-GFCI protected -Provide breaker lockout device for a water heater circuit

### **Comments:**