



4236 Highway 30 West  
P.O. Box 213  
Annville, KY. 40402

**DATE: April 28, 2021**

**FROM: EMR, llc.**

**RE: PETLAND @**

**460 NW Chipman Road**

**Lee's Summit, MO. 64063**

**To Whom It May Concern:**

**This is a letter to serve as a response to the MPE review comments made on the project listed above.**

**Mechanical:**

- 1) Duct mounted smoke detectors were moved to the return side of the RTU's. See sheets M-1 and M-2**

**Plumbing:**

- 1) A note was added to sheet P1 pertaining to the shut off valves.**
- 2) Gas venting was added to the water heater detail on sheet P-4.**
- 3) Type of plumbing materials were added to sheets P-1, P-2 and P-3.**

**Fire**

- 1) An additional exit sign was added on sheet E-1.**

**If you have any questions concerning this letter please feel to give me a call at your convenience, (606) 364-2886**

**Sincerely**

**Eric Engell**