

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210199
Address: 1740 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Michael Harkins	Failed	Friday, April 30, 2021

Corrective Action Required:

1	Misc	COMPLETE LABELING OF SERVICE PANEL INSULATE DRAIN UNDER SINK WOMENS RESTROOM REMOVE ABANDONED MC CABLE BACK ROOM CEILING (OR LAND IN A BOX WITH COVER PLATE)
---	------	--

Comments: