

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20210969	Date:	May 03, 2021
Project Title:	MILAN LASER HAIR REMOVAL	Applicant:	
Location:			
1728 NW CHIPMAN RD, LEES SUMMIT, MO 64081		ABSOLUTE FIRE INC	
Type of Work:		13906 CENTURY LN	
Occupancy Group:	B	GRANDVIEW, MO 64030	
Description:	TENANT FINISH FOR LASER HAIR		
REMOVAL		Primary: (816) 737-9991	
***address is actually 1728 NW Chipman Rd - fixed			
digitally but "printed" docs in permit remain incorrect.			
- jdf 04/12/21			
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.