

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20201014  
Address: 2751 NE DOUGLAS ST, Unit:V, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Khanh Nguyen	Failed	Monday, May 03, 2021

Corrective Action Required:

1	Misc	-Bond raceways and enclosure enclosing the service conductors per NEC 250.92(B) **Not done
		-Tighten grounding connection to ufer rebar **No access

**Comments:**