

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204747
Address: 4406 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Monday, May 03, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

-NO CITY APPROVED PLANS ON SITE -

-REMOVE ALL STANDING WATER FROM BASEMENT TO ALLOW FOR INSPECTION -

Comments: