

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210283
Address: 317 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Tuesday, May 04, 2021

Corrective Action Required:

1	Misc	-NO CITY APPROVED PLANS, TRUSS DRAWINGS & LAYOUT ON SITE - NO INSPECTION NAIL STHD14 HOLDDOWNS PROVIDE SOLID BLOCKING AT SHEATHING BREAKS AT PFH PORTAL FRAME
---	------	---

Comments: