



4236 Highway 30 West  
P.O. Box 213  
Annville, KY. 40402

**DATE: May 4, 2021, 2021**

**FROM: EMR, llc.**

**RE: PETLAND @**

**464 NW Chipman Road**

**Lee's Summit, MO. 64063**

**To Whom It May Concern:**

**This is a letter is to serve as a response to the MPE review comments made on the project listed above.**

**Plumbing:**

- 1) Gas venting was added to the water heater detail on sheet P-4.**
- 2) The requirement of a hammer arrestor was added to sheets P-1, P-2 and P-3.**

**Structural:**

- 1) The weight for the proposed roof top units to be installed over this space is 600 pounds each with corner weights at an average of 150 pounds.**

**If you have any questions concerning this letter please feel to give me a call at your convenience, (606) 364-2886**

**Sincerely**

**Eric Engell**

