CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202150

Address: 1414 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Tuesday, May 04, 2021

Residential

Corrective Action Required:

1 Misc -Pay all fees due before final occupancy

- -Provide erosion control at back of house before any further inspections
- -Sidewalk inspection still pending
- -Final grade and sod
- -Splash blocks and sump discharge
- -Adjust garage door to be self closing and latching
- -Install door hardware on garage door
- -Install receptacles, spark rings, and cover plates at floor boxes in living and

dining rooms

- -1" clearance to combustibles required at B vent at furnace
- -Receptacle required within 25' of furnace -Provide anti-syphon device at hose bib

Comments: